

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-18-11-30-03

Product: Wood veneer floor covering with different wood species in the top layer,
core layer: Eucalyptus 12.4 mm, UV lacquer
dimensions: length (300-2100) mm x width (60-220) mm x thickness (9-22) mm

Producer: Baroque Timber Industries (Zhongshan) Ltd.
Suian Industrial Zone, Gangkou Town, ZhongShan City, GuangDong 528447
CHINA

Order: Testing of selected properties according to EN 14342:2013 for CE-labelling

Test report: 278003/127

Test results: *The above mentioned Wood veneer floor covering can be classified regarding to both properties according to EN 14342:2013 (CE-labelling) as follows:*


Property	Results	Declaration according to EN 14342:2013
Formaldehyde emission according to EN 717-1:2005	< LOD (96 h)	class E1
Content of PCP according to CEN/TR 14823:2004	< LOQ	PCP ≤ 5 x 10 ⁻⁶ⁿ

LOD = Limit of Detection
LOQ = Limit of quantitation

Dresden, 30/11/2018



Head of laboratory

Engineer in charge